



STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

1410 North Hilton • Boise, Idaho 83706-1255 • (208) 373-0502

Dirk Kempthorne, Governor
Toni Hardesty, Director

April 8, 2005

Certified Mail No. 7000 1670 0013 8129 0324

Mr. Charles H. Ross
General Manager
Agrium Conda Phosphate Operations
3010 Conda Rd
Soda Springs Id 83276

RE: Facility ID No. 029-00003, Agrium, Soda Springs
Final Tier I Operating Permit

Dear Mr. Ross:

The Idaho Department of Environmental Quality (DEQ) is issuing Tier I Operating Permit No. TI-040308 for modifications regarding the East Sulfuric Acid Plant at the Agrium Conda Phosphate Operations facility near Soda Springs in accordance with IDAPA 58.01.01.300 through 386, *Rules for the Control of Air Pollution in Idaho (Rules)*.

The enclosed permit is effective immediately and summarizes the applicable requirements for your facility. The enclosed operating permit is based on the information contained in your permit application materials received on March 26, 2004, April 6, 2004 and May 7, 2004.

Since this project does not significantly change the terms of your permit, DEQ will not contact you regarding a meeting to discuss the terms of the permit. However, if you wish to meet to discuss the permit terms and requirements, you may contact Peter Wagner of the Pocatello Regional Office to schedule a meeting. If a meeting is scheduled, DEQ recommends the following representatives attend the meeting: your facility's plant manager, responsible official, environmental contact, and any operations staff responsible for day-to-day compliance with permit conditions.

Pursuant to IDAPA 58.01.23, you, as well as any other entity, may have the right to appeal this final agency action within 35 days of the date of this decision. However, prior to filing a petition for a contested case, I encourage you to call Dan Pitman at (208) 373-0502 to address any questions or concerns you may have with the enclosed permit.

Sincerely,

A handwritten signature in cursive script that reads "Martin Bauer".

Martin Bauer, Administrator
Air Quality Division

MB/DP/sd

Permit No. TI-040308

Enclosure



**Air Quality
TIER I OPERATING PERMIT**

**State of Idaho
Department of Environmental Quality**

PERMIT NO.: T1-040308

FACILITY ID NO.: 029-00003

AQCR: 61 **CLASS:** A

SIC: 2874 **ZONE:** 12

UTM COORDINATE (km): 455.8, 4731.8

1. PERMITTEE

Nu-West Industries, Inc.; Agrium Conda Phosphate Operations

2. PROJECT

Tier I Operating Permit

3. MAILING ADDRESS

3010 Conda Road

CITY

Soda Springs

STATE

ID

ZIP

83276

4. FACILITY CONTACT

Monty Johnson

TITLE

Environmental Manager

TELEPHONE

(208) 547-4381 ext. 263

5. RESPONSIBLE OFFICIAL

Charles H. Ross

TITLE

General Manager

TELEPHONE

(208) 547-4381

6. EXACT PLANT LOCATION

7 miles north of Soda Springs, 1.2 miles east of Highway 34

COUNTY

Caribou

7. GENERAL NATURE OF BUSINESS & KINDS OF PRODUCTS

Phosphate-based fertilizer products

8. PERMIT AUTHORITY

This Tier I operating permit is issued pursuant to Idaho Code §39-115 and the *Rules for the Control of Air Pollution in Idaho*, IDAPA 58.01.01.300 through 386. The permittee shall comply with the terms and conditions of this permit.

This permit incorporates all applicable terms and conditions of prior air quality permits issued by the Department of Environmental Quality (DEQ) for the permitted source, unless the permittee emits toxic pollutants subject to State-only requirements pursuant to IDAPA 58.01.01.210, and the permittee elects not to incorporate those terms and conditions into this operating permit.

The effective date of this permit is the date of signature by the DEQ on the cover page.


TONI HARDESTY, DIRECTOR
DEPARTMENT OF ENVIRONMENTAL QUALITY

DATE ISSUED: April 8, 2005

DATE EXPIRES: October 28, 2006

Table of Contents

ACRONYMS, UNITS, AND CHEMICAL NOMENCLATURE	3
1. FACILITY-WIDE CONDITIONS.....	4
2. GRANULATION PLANT	13
3. DRY PRODUCT TRANSFER, STORAGE, AND LOADOUT	22
4. EAST SULFURIC ACID PLANT	24
5. NEBRASKA BOILER (B-5)	31
6. WET PROCESS PHOSPHORIC ACID PLANT.....	47
7. RESERVED	60
8. CLEAVER-BROOKS BOILER.....	61
9. INSIGNIFICANT ACTIVITIES.....	78
10. TIER I OPERATING PERMIT GENERAL PROVISIONS	79
11. APPENDIX A – 40 CFR 63 SUBPART A REQUIREMENTS	85

Acronyms, Units, And Chemical Nomenclature

acfm	actual cubic feet per minute
AIRS	Aerometric Information Retrieval System
AQCR	Air Quality Control Region
ASTM	American Society of Testing and Materials
CFR	Code of Federal Regulations
CO	carbon monoxide
DEQ	Department Environmental Quality
dscf	dry standard cubic feet
EPA	U.S. Environmental Protection Agency
gpm	gallons per minute
gr	grain (1 lb = 7,000 grains)
gr/dscf	grains per dry standard cubic foot
HAPs	hazardous air pollutants
IDAPA	a numbering designation for all administrative rules in Idaho promulgated in accordance with the Idaho Administrative Procedures Act
km	kilometer
lb/hr	pound per hour
MACT	Maximum Available Control Technology
MMBtu/hr	million British thermal units per hour
NESHAP	Nation Emission Standards for Hazardous Air Pollutants
NO _x	nitrogen oxides
NSPS	New Source Performance Standards
O&M	operations and maintenance
P ₂ O ₅	phosphorous pentoxide
PM	particulate matter
PM ₁₀	particulate matter with an aerodynamic diameter of 10 micrometers or less
ppm	parts per million
PSD	Prevention of Significant Deterioration
PTC	permit to construct
PW	process weight
RMP	Risk Management Plan
SIC	Standard Industrial Classification
scf	standard cubic feet
SIP	State Implementation Plan
SO ₂	sulfur dioxide
T/yr	tons per year
U.S.C.	United States Code
VOC	volatile organic compound

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

1. FACILITY-WIDE CONDITIONS

The following requirements apply generally to emissions units at the facility.

Table 1.1 FACILITY-WIDE APPLICABLE REQUIREMENTS SUMMARY

Permit Conditions	Parameter	Permit Limit / Standard Summary	Applicable Requirements Reference	Monitoring and Record-keeping Requirements
1.1	Fugitive emissions	Reasonable precautions	IDAPA 58.01.01.650-651	1.2, 1.3, 1.4, 1.11
1.5	Odorous gases, liquids, or solids	No emissions that cause air pollution	IDAPA 58.01.01.775-776	1.6, 1.11
1.7	Visible emissions	20% opacity for no more than three minutes in any 60-minute period	IDAPA 58.01.01.625	1.8, 1.11
1.9	Excess emissions	Compliance with IDAPA 58.01.01.130-136	IDAPA 58.01.01.130	1.9-1.9.5, 1.11
1.12	Open burning	In accordance with IDAPA 58.01.01.600-616	IDAPA 58.01.01.600-616	1.11
1.13	Asbestos	Compliance with 40 CFR 61, Subpart M	40 CFR 61, Subpart M	1.11, 1.13
1.14	Accidental release prevention	Compliance with 40 CFR 68.215(a)(2)	40 CFR 68.10(a)	1.11, 1.14
1.15	PM ₁₀ , PM, NO _x , SO ₂ , CO, VOC, opacity	Test methods	IDAPA 58.01.01.157	1.11, 1.16
1.17	Fuel-burning equipment PM standard	Grain-loading	IDAPA 58.01.01.676-677	1.17.1, 1.11
1.18, 1.19	Fuel sulfur content	<u>Fuel Oil</u> ASTM grade No. 1 – 0.3% by weight ASTM grade No. 2 – 0.5% by weight <u>Coal</u> 1% by weight	IDAPA 58.01.01.728 and 729	1.11, 1.20
1.21	Recycling and emissions reduction	Reduce emissions of Class I and Class II refrigerants in accordance with 40 CFR 82, Subpart F	40 CFR 82, Subpart F	1.11, 1.21
1.22	Fugitive dust emissions	Visible emissions at property boundary not to exceed 3 minutes in any 60-minute period	PTC No. 029-00003; Permit Condition 1.2, 7/12/02	1.2, 1.3, 1.4, 1.11
1.23	Fluoride emissions	0.3 pounds fluoride per ton P ₂ O ₅ input	IDAPA 58.01.01.75, 5/01/94	1.24
1.25	Operation of ambient monitors	Operate 2 PM ₁₀ and 1 SO ₂ monitors	Consent Order, Condition 10, 10/24/73	1.11

Fugitive Emissions

- 1.1 All reasonable precautions shall be taken to prevent PM from becoming airborne in accordance with IDAPA 58.01.01.650-651.

[IDAPA 58.01.01.650, 651, 5/1/94]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 1.2 The permittee shall monitor and maintain records of the frequency and the method(s) used (i.e., water, chemical dust suppressants, etc.) to reasonably control fugitive emissions.
[IDAPA 58.01.01.322.06, 07, 5/1/94]

- 1.3 The permittee shall maintain records of all fugitive dust complaints received. The permittee shall take appropriate corrective action as expeditiously as practicable after a valid complaint is received. The records shall include, at a minimum, the date that each complaint was received and a description of the following: the complaint, the permittee's assessment of the validity of the complaint, any corrective action taken, and the date the corrective action was taken.
[IDAPA 58.01.01.322.06, 07, 5/1/94]

- 1.4 The permittee shall conduct a monthly facility-wide inspection of potential sources of fugitive emissions, during daylight hours and under normal operating conditions, to ensure that the methods used to reasonably control fugitive emissions are effective. If fugitive emissions are not being reasonably controlled, the permittee shall take corrective action as expeditiously as practicable. The permittee shall maintain records of the results of each monthly fugitive emission inspection. The records shall include, at a minimum, the date of each inspection and a description of the following: the permittee's assessment of the conditions existing at the time fugitive emissions were present (if observed), any corrective action taken in response to the fugitive emissions, and the date the corrective action was taken.
[IDAPA 58.01.01.322.06, 07, 5/1/94; IDAPA 58.01.01.322.08, 4/5/00]

Odors

- 1.5 No person shall allow, suffer, cause, or permit the emission of odorous gases, liquids, or solids to the atmosphere in such quantities as to cause air pollution.
[IDAPA 58.01.01.775-776, 5/1/94]
- 1.6 The permittee shall maintain records of all odor complaints received. If the complaint has merit, the permittee shall take appropriate corrective action as expeditiously as practicable. The records shall include, at a minimum, the date that each complaint was received and a description of the following: the complaint, the permittee's assessment of the validity of the complaint, any corrective action taken, and the date the corrective action was taken.
[IDAPA 58.01.01.322.06, 07 (state-only), 5/1/94]

Visible Emissions

- 1.7 No person shall discharge any air pollutant to the atmosphere from any point of emission for a period or periods aggregating more than three minutes in any 60-minute period which is greater than 20% opacity as determined by procedures contained in IDAPA 58.01.01.625. These provisions shall not apply when the presence of uncombined water, nitrogen oxides, and/or chlorine gas are the only reason(s) for the failure of the emission to comply with the requirements of this section.
[IDAPA 58.01.01.625, 4/5/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 1.8 In addition to the specific requirements in Permit Conditions 4.8.3 and 7.8.2, the permittee shall conduct a monthly facility-wide visible emission inspection of potential sources of visible emissions during daylight hours and under normal operating conditions. The visible emissions inspection shall consist of a see/no see evaluation for each potential source. If any visible emissions are present from any point of emission, the permittee shall either take appropriate corrective action as expeditiously as practicable, or perform a Method 9 opacity test in accordance with the procedures outlined in IDAPA 58.01.01.625. A minimum of 30 observations shall be recorded when conducting the opacity test. If opacity is greater than 20% for a period or periods aggregating more than three minutes in any 60-minute period, the permittee shall take all necessary corrective action and report the exceedance in its annual compliance certification and in accordance with IDAPA 58.01.01.130-136. The permittee shall maintain records of the results of each monthly visible emission inspection and each opacity test when conducted. The records shall include, at a minimum, the date and results of each inspection and test and a description of the following: the permittee's assessment of the conditions existing at the time visible emissions are present (if observed), any corrective action taken in response to the visible emissions, and the date corrective action was taken.

[IDAPA 58.01.01.322.06, 07, 5/1/94; IDAPA 58.01.01.322.08, 4/5/00]

Excess Emissions

- 1.9 In addition to the specific requirements in Permit Conditions 2.17.2, 5.22.2, and 6.27.2, the permittee shall comply with the procedures and requirements of IDAPA 58.01.01.130-136 for excess emissions. The provisions of IDAPA 58.01.01.130-136 shall govern in the event of conflicts between Permit Condition 1.9 and the regulations of IDAPA 58.01.01.130-136.

- 1.9.1 The person responsible for or in charge of a facility during an excess emissions event shall, with all practicable speed, initiate and complete appropriate and reasonable action to correct the conditions causing such excess emissions event, to reduce the frequency of occurrence of such events, to minimize the amount by which the emission standard is exceeded, and shall, as provided below or upon request of DEQ, submit a full report of such occurrence including a statement of all known causes and of the scheduling and nature of the actions to be taken.

[IDAPA 58.01.01.132, 4/5/00]

- 1.9.2 In all cases where startup, shutdown, or scheduled maintenance of any equipment or emission unit is expected to result or results in an excess emissions event, the owner or operator of the facility or emissions unit generating the excess emissions shall demonstrate compliance with IDAPA 58.01.01.133.01(a) through (d), including, but not limited to:

[IDAPA 58.01.01.133, 4/5/00]

- A prohibition of any scheduled startup, shutdown, or maintenance resulting in excess emissions shall occur during any period in which an Atmospheric Stagnation Advisory and/or a Wood Stove Curtailment Advisory has been declared by DEQ; and
- Notifying DEQ of the excess emissions event as soon as reasonably possible, but no later than two hours prior to the start of the excess emission event unless the owner or operator demonstrates to DEQ's satisfaction that a shorter advanced notice was necessary.

[IDAPA 58.01.01.133.01.a, 3/20/97]

[IDAPA 58.01.01.133.01.b, 4/5/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- The owner or operator of a source of excess emissions shall report and record the information required pursuant to Permit Conditions 1.9.4 and 1.9.5 and IDAPA 58.01.01.135 and 136 for each excess emissions event due to startup, shutdown, or scheduled maintenance.

[IDAPA 58.01.01.133.01.c, 3/20/97]

- 1.9.3 In all cases where upset or breakdown of equipment or an emissions unit, or the initiation of safety measures, results or may result in an excess emissions event, the owner or operator of the facility or emissions unit generating the excess emissions shall demonstrate compliance with IDAPA 58.01.01.134.01(a) and (b) and the following:

[IDAPA 58.01.01.134, 4/5/00]

- 1.9.3.1 For all equipment or emissions units from which excess emissions result during upset or breakdown conditions, or for other situations that may necessitate the implementation of safety measures which cause excess emissions, the facility owner or operator shall comply with the following:

[IDAPA 58.01.01.134.02, 4/5/00]

- The owner or operator shall immediately undertake all appropriate measures to reduce and, to the extent possible, eliminate excess emissions resulting from the event and to minimize the impact of such excess emissions on the ambient air quality and public health.

[IDAPA 58.01.01.134.02.a, 4/5/00]

- The owner or operator shall notify DEQ of any upset, breakdown, or safety event that results in excess emissions. Such notification shall identify the time, specific location, equipment or emissions unit involved, and (to the extent known) the cause(s) of the occurrence. The notification shall be given as soon as reasonably possible, but no later than 24 hours after the event, unless the owner or operator demonstrates to DEQ's satisfaction that the longer reporting period was necessary.

[IDAPA 58.01.01.134.02.b, 4/5/00]

- The owner or operator shall report and record the information required pursuant to Permit Conditions 1.9.4 and 1.9.5 and IDAPA 58.01.01.135 and 136 for each excess emissions event caused by an upset, breakdown, or safety measure.

[IDAPA 58.01.01.134.02.c, 3/20/97]

- 1.9.3.2 During any period of excess emissions caused by upset, breakdown, or operation under facility safety measures, DEQ may require the owner or operator to immediately reduce or cease operation of the equipment or emissions unit causing the excess emissions until such time as the condition causing the excess emissions has been corrected or brought under control. Such action by DEQ shall be taken upon consideration of the factors listed in IDAPA 58.01.01.134.03 and after consultation with the facility owner or operator.

[IDAPA 58.01.01.134.03 4/5/00]

- 1.9.4 A written report for each excess emissions event shall be submitted to DEQ by the owner or operator no later than 15 days after the beginning of such an event. Each report shall contain the information specified in IDAPA 58.01.01.135.02.

[IDAPA 58.01.01.135.01, 3/20/97; IDAPA 58.01.01.135.02, 4/5/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 1.9.5 The owner or operator shall maintain excess emissions records at the facility for the most recent five-calendar-year period. The excess emissions records shall be made available to DEQ upon request. The excess emissions records shall include the information requested by IDAPA 58.01.01.136.03(a) and (b) as summarized in the following:

[IDAPA 58.01.01.136.01, 02, 3/20/97; IDAPA 58.01.01.136.03, 4/5/00]

- An excess emissions record book for each emissions unit or piece of equipment containing copies of all reports that have been submitted to DEQ pursuant to IDAPA 58.01.01.135 for the particular emissions unit or equipment; and

[IDAPA 58.01.01.136.03.a, 4/5/00]

- Copies of all startup, shutdown, and scheduled maintenance procedures and upset, breakdown, or safety preventative maintenance plans which have been developed by the owner or operator in accordance with IDAPA 58.01.01.133 and 134, and facility records as necessary to demonstrate compliance with such procedures and plans.

[IDAPA 58.01.01.136.03.b, 3/20/97; IDAPA 58.01.01.130-136, 4/5/00
(state-only, federally-enforceable upon approval into the SIP);
IDAPA 58.01.01.322.08.b, 3/23/98]

Reports and Certifications

- 1.10 All periodic reports and certifications required by this permit shall be submitted to DEQ within 30 days of the end of each specified reporting period. Excess emissions reports and notifications shall be submitted in accordance with IDAPA 58.01.01.130-136.

Reports, certifications, and notifications shall be submitted to:

Air Quality Permit Compliance
Department of Environmental Quality
Pocatello Regional Office
444 Hospital Way, #300
Pocatello, ID 83201
Phone: (208) 236-6160
Fax: (208) 236-6168

The periodic compliance certification required by General Provision 21 shall also be submitted within 30 days of the end of the specified reporting period to:

EPA Region 10
Air Operating Permits, OAQ-107
1200 Sixth Ave.
Seattle, WA 98101

[IDAPA 58.01.01.322.08, 11, 5/1/94]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Monitoring and Recordkeeping

- 1.11 The permittee shall maintain sufficient recordkeeping to assure compliance with all of the terms and conditions of this operating permit. Recording of monitoring information shall include, but not be limited to the following: (a) the date, place, and times of sampling or measurements; (b) the date analyses were performed; (c) the company or entity that performed the analyses; (d) the analytical techniques or methods used; (e) the results of such analyses; and (f) the operating conditions existing at the time of sampling or measurement. All monitoring records and support information shall be retained for a period of at least five years from the date of the monitoring sample, measurement, report, or application. Supporting information includes, but is not limited to, all calibration and maintenance records, all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. All records required to be maintained by this permit shall be made available in either hard copy or electronic format to DEQ representatives upon request.

[IDAPA 58.01.01.322.07, 5/1/94]

Open Burning

- 1.12 The permittee shall comply with the requirements of IDAPA 58.01.01.600-616, *Rules for Control of Open Burning*.

[IDAPA 58.01.01.600-616, 5/1/94]

Renovation/Demolition

- 1.13 The permittee shall comply with all applicable portions of 40 CFR 61, Subpart M when conducting any renovation or demolition activities at the facility.

[40 CFR 61, Subpart M]

Regulated Substances for Accidental Release Prevention

- 1.14 This facility is subject to Part 68 and shall certify compliance with all requirements of 40 CFR 68, including the registration and submission of the RMP, as part of the annual compliance certification required by 40 CFR 70.6(c)(5).
- [40 CFR 68.215(a)(2); IDAPA 58.01.01.322.11, 5/1/94; 40 CFR 68.215(a)(II)] **Test Methods**
- 1.15 If testing is required, the permittee shall use the following test methods described in Table 1.2 to measure the pollutant emissions.

Table 1.2 EPA REFERENCE TEST METHODS

Pollutants	Test Method*	Special Conditions
PM ₁₀	EPA Method 201.a EPA Method 202	
PM	EPA Method 5	
NO _x	EPA Method 7	
SO ₂	EPA Method 6	
CO	EPA Method 10	
VOC	EPA Method 25	
Opacity	EPA Method 9	If an NSPS source, IDAPA 58.01.01.625 and Method 9; otherwise, IDAPA 58.01.01.625 only.

* Or DEQ-approved alternative in accordance with IDAPA 58.01.01.157

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Compliance Testing

- 1.16 If testing is required, the permittee shall provide notice of intent to test to DEQ at least 15 days prior to the scheduled test or shorter time period as provided in a permit, order, consent decree, or by DEQ approval. DEQ may, at its option, have an observer present at any emissions tests conducted on a source. DEQ requests that such testing not be performed on weekends or state holidays.

All testing shall be conducted in accordance with the procedures in IDAPA 58.01.01.157. Without prior DEQ approval, any alternative testing is conducted solely at the permittee's risk. If the permittee fails to obtain prior written approval by DEQ for any testing deviations, DEQ may determine that the testing does not satisfy the testing requirements. Therefore, prior to conducting any compliance test, the permittee is encouraged to submit in writing to DEQ, at least 30 days in advance, the following for approval:

- The type of test method to be used
- Any extenuating or unusual circumstances regarding the proposed test
- The proposed schedule for conducting and reporting the test

Within 30 days following the date in which a compliance test required by this permit is concluded, the permittee shall submit to DEQ a compliance test report for the respective test. The compliance test report shall include all process operating data collected during the test period as well as the test results, raw test data, and associated documentation, including any approved test protocol.

The proposed test date(s), test date rescheduling notice(s), compliance test report, and all other correspondence shall be sent to:

Air Quality Permit Compliance
Department of Environmental Quality
Pocatello Regional Office
444 Hospital Way, # 300
Pocatello, ID 83201
Phone: (208) 236-6160

Fax: (208) 236-6168

[IDAPA 58.01.01.157, 4/5/00; IDAPA 58.01.01.322.06, 08.a, 09, 5/1/94]

Fuel-burning Equipment

- 1.17 The permittee shall not discharge to the atmosphere from any fuel-burning equipment particulate matter in excess of 0.015 gr/dscf of effluent gas corrected to 3% oxygen by volume for gas.
[IDAPA 58.01.01.676-677, 5/1/94]
- 1.17.1 The boilers and heaters not listed as insignificant emission units (Section 9) shall be fired on natural gas exclusively.
[IDAPA 58.01.01.322.01, 3/19/99]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Sulfur Content

- 1.18 No person shall sell, distribute, use, or make available for use any distillate fuel oil containing more than the following percentages of sulfur:

- ASTM Grade 1 fuel oil - 0.3% by weight.
- ASTM Grade 2 fuel oil - 0.5% by weight.

[IDAPA 58.01.01.728, 5/1/94]

- 1.19 No person shall sell, distribute, use or make available for use, any coal containing greater than 1% sulfur by weight.

[IDAPA 58.01.01.729, 5/1/94]

- 1.20 The permittee shall maintain documentation of supplier verification of distillate fuel oil sulfur content and coal sulfur content on an as-received basis.

[IDAPA 58.01.01.322.01, 3/19/99]

Recycling and Emissions Reductions

- 1.21 The permittee shall comply with applicable standards for recycling and emissions reduction pursuant to 40 CFR 82, Subpart F, Recycling and Emissions Reduction.

[40 CFR 82, Subpart F]

Fugitive Dust Emissions

- 1.22 Fugitive emissions shall not be observed leaving the property for a period or periods aggregating more than three minutes in any 60-minute period. Fugitive visible emissions shall be determined by EPA Reference Method 22, as described in 40 CFR 60, Appendix A, or by a DEQ-approved alternative method.

[IDAPA 58.01.01.203.02, 5/1/94; IDAPA 58.01.01.211.01, 5/1/94;
PTC No. 029-00003, Permit Condition 1.2, 7/12/00]

Rules for Control of Fluoride Emissions

- 1.23 No person shall allow, suffer, cause or permit the discharge into the atmosphere of total fluoride emissions in gaseous and in particulate form, expressed as fluoride (F-) from the phosphate fertilizer plant sources in Permit Conditions 2 and 6 in excess of 0.3 pounds of fluoride per ton of P_2O_5 input to the phosphate fertilizer plant, calculated at maximum-rated capacity.

[IDAPA 58.01.01.751.01, 5/1/94]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Monitoring, Testing, and Reporting Requirements

- 1.24 Compliance with IDAPA 58.01.01.751.01 will be adjudged upon the results of the continuing program of fluoride sampling of potential grazing areas and alfalfa-growing areas conducted by DEQ. Sampling conducted by any person subject to IDAPA 58.01.01.751 may be accepted for determining compliance with IDAPA 58.01.01.751.01 if such sampling is conducted at sites approved by DEQ in advance of sampling, using analytical procedures appearing in the Procedures Manual for Air Pollution Control, Section I (Source Test Methods) or equivalent methods approved by DEQ in advance of sampling. Compliance with IDAPA 58.01.01.751.01 shall be demonstrated by testing methods approved in advance by DEQ. When approved by the Director in advance of sampling, engineering calculations may be submitted in lieu of emission data. Monitoring and reporting requirements shall be included in operating permits granted to each facility.

[IDAPA 58.01.01.751.02, 5/1/94]

Operation of Ambient Monitors

- 1.25 The permittee shall operate two PM_{10} monitors and one continuous ambient SO_2 monitor at sites approved by DEQ. Results of the above described monitoring shall be submitted to DEQ monthly.

[Consent Order, Condition 10, 10/24/73]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

2. GRANULATION PLANT

Summary Description

The following is a narrative description of the dry fertilizer granulation plant regulated in this Tier I operating permit. This description is for informational purposes only.

The granulation plant produces two different grades of dry products. Phosphoric acid from the phosphoric acid plant and ammonia, which is purchased from outside the plant, are the primary raw materials. The basic reaction involved in the different products is the neutralization of the phosphoric acid by the ammonia. This generates a large quantity of heat and is responsible for the steam plume which may be seen exiting the Granulation stack.

At various points in the process, dust, fluorine fumes, or ammonia fumes are generated. A series of scrubbers are used to remove these fumes from the air exiting the plant. Phosphoric acid and water are used as the scrubbing media.

Table 2.1 below describes the devices used to control emissions from the granulation plant.

Table 2.1 EMISSIONS UNITS AND EMISSIONS CONTROL DEVICES

Source Code	Emission Unit(s) / Process(es)	Emission Control Device	Emission Point
S-Fa-1	granulation plant	A-Fa-1a Venturi Scrubber (wet, Phosphoric Acid)	P-Fa-1/2 (Sources Fa-1 and Fa-2 have a common exhaust)
		A-Fa-1b Spray tower scrubber (water)	
S-Fa-2		A-Fa-2a Multiple Cyclone (dry)	
		A-Fa-2b Venturi Scrubber (wet, Phosphoric Acid)	
S-Fa-3		A-Fa-3 Baghouse	P-Fa-3

Table 2.2 contains only a summary of the requirements that apply to the granulation plant. Specific permit requirements are listed below Table 2.2.

Table 2.2 APPLICABLE REQUIREMENTS SUMMARY

Permit Conditions	Parameter	Permit Limit / Standard Summary	Applicable Requirements Reference	Operating, Monitoring, and Recordkeeping Requirements
2.1	Fluoride emissions	0.058 lb/ton equivalent P ₂ O ₅ feed	40 CFR 63.622 ⁽¹⁾	2.3, 2.4, 2.5, 2.6, 2.7, 2.8, 2.10, 2.11, 2.12, 2.13, 2.15, 2.17, 2.18, 2.19, 2.20, 2.21, 2.22
2.2	Particulate matter	Process weight limitations	IDAPA 58.01.01.701	2.5, 2.9, 2.14, 2.16

¹ If any requirement in this permit conflicts with any requirement contained in 40 CFR 63 the requirement in 40 CFR 63 shall control.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Permit Limits / Standard Summary

2.1 Fluoride - Diammonium and/or Monoammonium Phosphate Process Line

On and after the date on which the performance test required to be conducted by 40 CFR 63.7 and 63.626 is completed, no owner or operator subject to the provisions of 40 CFR 63, Subpart BB shall cause to be discharged into the atmosphere from any affected source any gases which contain total fluorides in excess of 29.0 grams/metric ton of equivalent P_2O_5 feed (0.0580 lb/ton).

[40 CFR 63.623(a); PTC No. 029-00003, pg. 18, Permit Condition 1.1, 7/12/00]

2.2 PM - Process Weight Rate Limitations

No person shall emit into the atmosphere from any process or process equipment commencing operation on or after October 1, 1979, PM in excess of the amount shown by the following equations, where E is the allowable emission from the entire source in pounds per hour, and PW is the process weight in pounds per hour.

- a. If PW is less than 9,250 lb/hr,

$$E = 0.045(PW)^{0.6}$$

- b. If PW is equal to or greater than 9,250 lb/hr,

$$E = 1.10(PW)^{0.25}$$

[IDAPA58.01.01.701, 4/5/00]

Operating Requirements

2.3 Pressure Drops and Flow Rates for Wet Scrubbers

On or after the date on which the performance test required to be conducted by 40 CFR 63.7 and 63.626 is completed, the owner/operator using a wet scrubbing emission control system must maintain daily averages of the pressure drop across each scrubber and of the flow rate of the scrubbing liquid to each scrubber within the allowable ranges established pursuant to the requirements of 40 CFR 63.625(f)(1) or (2).

[40 CFR 63.624; PTC No. 029-00003, pg. 18, Permit Condition 2.1, 7/12/00]

Monitoring & Recordkeeping Requirements

2.4 Throughput Monitoring Systems

Each owner or operator of a new or existing diammonium and/or monoammonium phosphate process line or granular triple superphosphate process line subject to the provisions of 40 CFR 63, Subpart BB shall install, calibrate, maintain, and operate a monitoring system which can be used to determine and permanently record the mass flow of phosphorus-bearing feed material to the process. The monitoring system shall have an accuracy of $\pm 5\%$ over its operating range.

[40 CFR 63.625(a); PTC No. 029-00003, pg. 18, Permit Condition 3.1, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

2.5 P₂O₅ Throughput

Each owner or operator of a new or existing diammonium and/or monoammonium phosphate process line or granular triple superphosphate process line subject to the provisions of 40 CFR 63, Subpart BB shall maintain a daily record of equivalent P₂O₅ feed by first determining the total mass rate in metric ton/hour of phosphorus bearing feed using a monitoring system for measuring mass flow rate which meets the requirements of 40 CFR 63.625(a) and then by proceeding according to 40 CFR 63.626(c)(3) (Permit Condition 2.13.1(3)).

[40 CFR 63.625(b); PTC No. 029-00003, pg. 18, Permit Condition 3.2, 7/12/00]

2.6 Pressure Drop Across Each Scrubber

Each owner or operator of a new or existing diammonium and/or monoammonium phosphate process line, granular triple superphosphate process line, or granular triple superphosphate storage building using a wet scrubbing emission control system shall install, calibrate, maintain, and operate a monitoring system which continuously measures and permanently records the pressure drop across each scrubber in the process scrubbing system in 15-minute block averages. The monitoring system shall be certified by the manufacturer to have an accuracy of ±5% over its operating range.

[40 CFR 63.625(c)(1); PTC No. 029-00003, pg. 19, Permit Condition 3.3, 7/12/00]

2.7 Liquid Flow Rate of Each Scrubber

Each owner or operator of a new or existing Diammonium and/or Monoammonium phosphate process line, granular triple superphosphate process line, or granular triple superphosphate storage building using a wet scrubbing emission control system shall install, calibrate, maintain, and operate a monitoring system which continuously measures and permanently records the flow rate of the scrubbing liquid to each scrubber in the process scrubbing system in 15-minute block averages. The monitoring system shall be certified by the manufacturer to have an accuracy of ±5% over its operating range.

[40 CFR 63.625(c)(2); PTC No. 029-00003, pg. 19, Permit Condition 3.4, 7/12/00]

2.8 Scrubber Pressure Drop and Liquid Flow Rate Ranges

Following the date on which the performance test required in 40 CFR 63.626 is completed, the owner or operator of a new or existing affected source using a wet scrubbing emission control system and subject to emissions limitations for total fluorides or particulate matter contained in 40 CFR 63, Subpart BB must establish allowable ranges for operating parameters using the methodology specified in either 2.8.1 or 2.8.2.

- 2.8.1 The allowable range for the daily averages of the pressure drop across each scrubber and of the flow rate of the scrubbing liquid to each scrubber in the process scrubbing system is ±20% of the baseline average value determined as a requirement of 40 CFR 63.626(c)(4) or (d)(4). The Administrator retains the right to reduce the ±20% adjustment to the baseline average values of operating ranges in those instances where performance test results indicate that a source's level of emissions is near the value of an applicable emissions standard, but in no instance shall the adjustment be reduced to less than #10%. The owner or operator must notify the Administrator of the baseline average value and must notify the Administrator each time that the baseline value is changed as a result of the most

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

recent performance test. When a source using the methodology of this paragraph is retested, the owner or operator shall determine whether new allowable ranges of baseline average values will be based upon the new performance test or (if the new performance test results are within the previously established range) whether there will be no change in the operating parameters derived from previous tests. When a source using the methodology of this paragraph is retested and the performance test results are submitted to the Administrator pursuant to 40 CFR 63.627(c)(1), 63.7(g)(1), and/or 63.10(d)(2), the owner or operator will indicate whether the operating range will be based on the new performance test or the previously established range. If the Administrator has not denied approval of the new operating ranges within 30 days of submission of the performance test results, the new ranges shall be deemed approved and the new baseline value shall then be effective on the 31st day following submission.

- 2.8.2 The owner or operator of any new or existing affected source shall establish, and provide to the Administrator for approval, allowable ranges for the daily averages of the pressure drop across and of the flow rate of the scrubbing liquid to each scrubber in the process scrubbing system for the purpose of assuring compliance with 40 CFR 63, Subpart BB. Allowable ranges may be based upon baseline average values recorded during previous performance tests using the test methods required in 40 CFR 63.626(c)(4) or (d)(4). As an alternative, the owner or operator can establish the allowable ranges using the results of performance tests conducted specifically for the purposes of this paragraph using the test methods required in 40 CFR 63, Subpart BB and established in the manner required in 40 CFR 63.626(c)(4) or (d)(4). The source shall certify that the control devices and processes have not been modified subsequent to the testing upon which the data used to establish the allowable ranges were obtained. The allowable ranges developed pursuant to the provisions of this paragraph must be submitted to the Administrator for approval. The owner or operator must request and obtain approval of the Administrator for changes to the allowable ranges. When a source using the methodology of this paragraph is retested, the owner or operator shall determine new allowable ranges of baseline average values unless the retest indicates no change in the operating parameters outside the previously established ranges. If the Administrator has not denied approval of the new operating ranges within 30 days of submission of the performance test results, the new ranges shall be deemed approved and the new baseline value shall then be effective on the 31st day following submission.

[40 CFR 63.625(f); PTC No. 029-00003, pg. 19, Permit Condition 3.5, 7/12/00]

2.9 Urea Storage Baghouse Pressure Drop

- 2.9.1 The permittee shall install, calibrate, maintain, and operate, in accordance with manufacturer specifications, equipment to continuously measure the pressure differential across the baghouse.
- 2.9.2 The pressure drop across the baghouse shall be maintained within the manufacturer and Operation & Maintenance (O&M) manual specifications when it is operated. Documentation of both the manufacturer's and O&M manual operating pressure drop specifications shall remain onsite at all times and shall be available to DEQ representatives upon request.
- 2.9.3 The permittee shall monitor and record the pressure drop across the baghouse on a weekly basis when it is operated.

[IDAPA 58.01.01.211.01, 5/1/94; PTC No. 029-00003, pg. 19, Permit Condition 3.6, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

2.10 Performance Testing for Existing Units

On or before the applicable compliance date in 40 CFR 63.630 and once per annum thereafter, each owner or operator of a phosphate fertilizers production plant subject to the provisions of 40 CFR 63, Subpart BB shall conduct a performance test to demonstrate compliance with the applicable emission standard for each existing diammonium and/or monoammonium phosphate process line. The owner or operator shall conduct the performance test according to the procedures in 40 CFR 63, Subpart A, and in 40 CFR 63.626.

[40 CFR 63.626(a)(1); PTC No. 029-00003, pg. 20, Permit Condition 3.7, 7/12/00]

2.11 Performance Testing for New Units

As required by 40 CFR 63.7(a)(2) and once per annum thereafter, each owner or operator of a phosphate fertilizer production plant subject to the provisions of 40 CFR 63, Subpart BB shall conduct a performance test to demonstrate compliance with the applicable emission standard for each new diammonium and/or monoammonium phosphate process line. The owner or operator shall conduct the performance test according to the procedures in 40 CFR 63, Subpart A and in 40 CFR 63.626.

[40 CFR 63.626(a)(2); PTC No. 029-00003, pg. 20, Permit Condition 3.8, 7/12/00]

2.12 Performance Test Methods

In conducting performance tests, each owner or operator of an affected source shall use as reference methods and procedures the test methods in 40 CFR 60, Appendix A, or other methods and procedures as specified in 40 CFR 63.626, except as provided in 40 CFR 63.7(f).

[40 CFR 63.626(b); PTC No. 029-00003, pg. 20, Permit Condition 3.9, 7/12/00]

2.13 Performance Testing - Fluorides

Each owner or operator of a new or existing diammonium and/or monoammonium phosphate process line shall determine compliance with the applicable total fluorides standards in 40 CFR 63.622 or 63.623, as specified in 2.13.1.

- 2.13.1 (1) The emission rate (E) of total fluorides shall be computed for each run using the following equation:

$$E = \left(\sum_{i=1}^N C_{si} Q_{sdi} \right) / (PK)$$

Where:

- E = emission rate of total fluorides, g/metric ton (lb/ton) of equivalent P₂O₅ feed.
- C_{si} = concentration of total fluorides from emission point "i," mg/dscm (mg/dscf).
- Q_{sdi} = volumetric flow rate of effluent gas from emission point "i," dscm/hr (dscf/hr).
- N = number of emission points associated with the affected facility.
- P = equivalent P₂O₅ feed rate, metric ton/hr (ton/hr).
- K = conversion factor, 1000 mg/g (453,600 mg/lb).

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (2) Method 13A or 13B (40 CFR 60, Appendix A) shall be used to determine the total fluorides concentration (C_{di}) and volumetric flow rate (Q_{sdi}) of the effluent gas from each of the emission points. If Method 13 B is used, the fusion of the filtered material described in Permit Condition 7.3.1.2 and the distillation of suitable aliquots of containers 1 and 2, described in Permit Conditions 7.3.3 and 7.3.4 in Method 13 A, may be omitted. The sampling time and sample volume for each run shall be at least one hour and 0.85 dscm (30 dscf).

- (3) The equivalent P_2O_5 feed rate (P) shall be computed using the following equation:

$$P = M_p R_p$$

Where:

M_p = total mass flow rate of phosphorus-bearing feed, metric ton/hr (ton/hr).

R_p = P_2O_5 content, decimal fraction.

- (i) The accountability system described in 40 CFR 63.625(a) and (b) shall be used to determine the mass flow rate (M_p) of the phosphorus-bearing feed.
- (ii) The P_2O_5 content (R_p) of the feed shall be determined using as appropriate the following methods (incorporated by reference -- see 40 CFR 63.14) specified in the Book of Methods Used and Adopted By The Association Of Florida Phosphate Chemists, Seventh Edition 1991, where applicable:
- (A) Section IX, Methods of Analysis for Phosphate Rock, No. 1 Preparation of Sample.
 - (B) Section IX, Methods of Analysis for Phosphate Rock, No. 3 Phosphorus -- P_2O_5 or $Ca_3(PO_4)_2$, Method A - Volumetric Method.
 - (C) Section IX, Methods of Analysis For Phosphate Rock, No. 3 Phosphorus- P_2O_5 or $Ca_3(PO_4)_2$, Method B - Gravimetric Quimociac Method.
 - (D) Section IX, Methods of Analysis For Phosphate Rock, No. 3 Phosphorus- P_2O_5 or $Ca_3(PO_4)_2$, Method C - Spectrophotometric Method.
 - (E) Section XI, Methods of Analysis For Phosphoric Acid, Superphosphate, Triple superphosphate, and Ammonium Phosphates, No. 3 Total Phosphorus- P_2O_5 , Method A -Volumetric Method.
 - (F) Section XI, Methods of Analysis For Phosphoric Acid, Superphosphate, Triple Superphosphate, and Ammonium Phosphates, No. 3 Total Phosphorus- P_2O_5 , Method B - Gravimetric Quimociac Method.
 - (G) Section XI, Methods of Analysis for Phosphoric Acid, Superphosphate, Triple Superphosphate, and Ammonium Phosphates, No. 3 Total Phosphorus- P_2O_5 , Method C - Spectrophotometric Method.
- (4) To comply with 40 CFR 63.625(f)(1) or (2), the owner or operator shall use the monitoring systems in 40 CFR 63.625(c) to determine the average pressure loss of the gas stream across each scrubber in the process scrubbing system and to determine the average flow rate of the scrubber liquid to each scrubber in the process scrubbing system during each of the total fluoride runs. The arithmetic averages of the three runs shall be used as the baseline average values for the purposes of 40 CFR 63.625(f)(1) or (2).

[40 CFR 63.626(c); PTC No. 029-00003, pg. 20, Permit Condition 3.10, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

2.14 Operations and Maintenance Manual Requirements

Within 60 days after startup, the permittee shall have developed an O&M manual for the Urea Storage Baghouse, which describes the procedures that will be followed to comply with Permit Condition 2.23 and the air pollution control device requirements contained in this permit. The manual shall remain onsite at all times and shall be available to DEQ representatives upon request.

[IDAPA 58.01.01.211.01, 5/1/94; PTC No. 029-00003, pg. 21, Permit Condition 3.11, 7/12/00]

- 2.15** Each owner or operator subject to the requirements of 40 CFR 63, Subpart BB shall comply with the recordkeeping requirements in 40 CFR 63.10. Requirements are included in Appendix A of this permit.

[40 CFR 63.627(b)]

2.16 Performance Test - Particulate Matter

The permittee shall conduct a compliance test on P-Fa-1/2, and P-Fa-3 in accordance with the procedures outlined in 40 CFR 60, Appendix A, Method 5, or a DEQ-approved alternative method, within 180 days of issuance of the permit.

If the particulate matter emission rate measured in the initial compliance test is less than or equal to 75% of the emission standard in Permit Condition 2.2, no further testing shall be required during the permit term. The process weight measured during the compliance test shall be PW in the equation. If the particulate matter emission rate measured during the compliance test is greater than 75%, but less than or equal to 90%, of the emission standard in Permit Condition 2.2, a second test shall be required in the third year of the permit term. If the particulate matter emission rate measured during the compliance test is greater than 90% of the emission standard in Permit Condition 2.2, the permittee shall conduct a compliance test annually.

[IDAPA 58.01.01.322.09, 5/1/94]

Reporting

2.17 Maximum Achievable Control Technology Performance Test Report

In accordance with 40 CFR 63.627(c), the owner or operator of an affected source shall comply with the reporting requirements specified in 40 CFR 63.10 as follows:

[40 CFR 63.627(c); PTC No. 029-00003, pg. 21, Permit Condition 4.1, 7/12/00]

2.17.1 Performance Test Report

As required by 40 CFR 63.10, the owner or operator shall report the results of the initial and annual performance tests as part of the notification of compliance status required in 40 CFR 63.9.

[40 CFR 63.627(c)(1)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

2.17.2 Excess Emissions Report

As required by 40 CFR 63.10, the owner or operator of an affected source shall submit an excess emissions report for any exceedance of an operating parameter limit. The report shall contain the information specified in 40 CFR 63.10. When no exceedances of an operating parameter have occurred, such information shall be included in the report. The report shall be submitted semiannually and shall be delivered or postmarked by the 30th day following the end of the calendar half. If exceedances are reported, the owner or operator shall report quarterly until a request to reduce reporting frequency is approved, as described in 40 CFR 63.10.

[40 CFR 63.627(c)(2)]

2.17.3 Summary Report

If the total duration of control system exceedances for the reporting period is less than 1% of the total operating time for the reporting period, the owner or operator shall submit a summary report containing the information specified in 40 CFR 63.10 rather than the full excess emissions report, unless required by the Administrator. The summary report shall be submitted semiannually and shall be delivered or postmarked by the 30th day following the end of the calendar half.

[40 CFR 63.627(c)(3)]

- 2.17.4** If the total duration of control system operating parameter exceedances for the reporting period is 1% or greater of the total operating time for the reporting period, the owner or operator shall submit a summary report and the excess emissions report.

[40 CFR 63.627(c)(4)]

- 2.18** Each owner or operator subject to the requirements of 40 CFR 63, Subpart BB shall comply with notification requirements in 40 CFR 63.9. Requirements are included in Appendix A of this permit.

[40 CFR 63.627(a)]

Phosphate Fertilizers Production Plant MACT Compliance Dates

- 2.19** Each owner or operator of an existing affected source at a phosphate fertilizers production plant shall achieve compliance with the requirements of 40 CFR 63, Subpart BB no later than June 10, 2002. Notwithstanding the requirements of 40 CFR 63.7(a)(2)(iii), each owner or operator of an existing affected source at a phosphate fertilizers production plant shall fulfill the applicable requirements of 40 CFR 63.626 no later than June 10, 2002.

[40 CFR 63.630(a)]

- 2.20** Each owner or operator of a phosphate fertilizers production plant that commences construction or reconstruction of an affected source after December 27, 1996 shall achieve compliance with the requirements of 40 CFR 63, Subpart BB upon startup of operations or by June 10, 1999, whichever is later.

[40 CFR 63.630(b)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Phosphate Fertilizers Production Plant Exemption From New Source Performance Standards

- 2.21 Any affected source subject to the provisions of 40 CFR 63, Subpart BB is exempted from any otherwise applicable new source performance standard contained in 40 CFR 60, Subpart V, Subpart W, or Subpart X. To be exempt, a source must have a current operating permit pursuant to Title V of the Act and the source must be in compliance with all requirements of 40 CFR 63, Subpart BB. For each affected source, this exemption is effective upon the date that the owner or operator demonstrates to the Administrator that the requirements of 40 CFR 63.624, 63.625 and 63.626 have been met.
[40 CFR 63.631]

Applicability of MACT General Provisions

- 2.22 The owner or operator shall comply with the requirements of the general provisions in 40 CFR 63, Subpart A as shown in Appendix A to 40 CFR 63, Subpart BB. Requirements are included in Appendix A of this permit.
[40 CFR 63.628; PTC No. 029-00003, Permit Condition 2.2, 7/12/00]

PTC General Provisions

- 2.23 The permittee shall at all times (except as provided in the *Rules*) maintain in good working order and operate as efficiently as practicable, all treatment or control facilities or systems installed or used to achieve compliance with the terms and conditions of this permit and other applicable Idaho laws for the control of air pollution.
[PTC No. 029-00003, General Provision B, 7/12/00]
- 2.24 The maximum allowable operating rate shall be limited to 120% of the average operating rate attained during any performance test period, for which a test protocol has been granted prior approval by DEQ, unless (1) the test demonstrates noncompliance; (2) a more restrictive operating limit is specified elsewhere in this permit; or (3) at such an operating rate, emissions would exceed any emissions limit(s) set forth in this permit.
[PTC No. 029-00003, General Provision F, 7/12/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

3. DRY PRODUCT TRANSFER, STORAGE, AND LOADOUT**Summary Description**

The following is a narrative description of the dry product transfer, storage, and loadout process regulated in this Tier I operating permit. This description is for informational purposes only.

Dry fertilizer from the granulation plant is conveyed to the shipping warehouse and stored until time to ship to customers. The warehouse holds approximately 60,000 tons of dry fertilizer products. Front-end loaders are used to transfer the product from the piles inside the warehouse to the feeders and conveyers. The fertilizer products are screened for size and loaded into railcars or trucks.

Table 3.1 describes the devices used to control dry product transfer, storage, and loadout.

Table 3.1 EMISSIONS UNITS AND EMISSIONS CONTROL DEVICES

Source Code	Emission Unit(s) / Process(es)	Emission Control Device
F-Fb-1	Dry product transfer	Enclosure
F-Fb-2	Dry product storage	Enclosure
F-Fc-1	Dry product loadout	Chemical dust suppressant

Table 3.2 contains only a summary of the requirements that apply to the dry product transfer, storage, and loadout process. Specific permit requirements are listed below Table 3.2.

Table 3.2 APPLICABLE REQUIREMENTS SUMMARY

Permit Condition	Parameter	Permit Limit / Standard Summary	Applicable Requirements Reference	Monitoring and Recordkeeping Requirements
3.1	Particulate matter	Process weight	IDAPA 58.01.01.702	None

Permit Limits / Standard Summary**3.1 PM - Process Weight Rate Limitations**

No person shall emit into the atmosphere from any process or process equipment operating prior to October 1, 1979, particulate matter in excess of the amount shown by the following equations, where E is the allowable emission from the entire source in pounds per hour, and PW is the process weight in pounds per hour.

- a. If PW is less than 17,000 lb/hr,

$$E = 0.045(PW)^{0.6}$$

- b. If PW is equal to or greater than 17,000 lb/hr,

$$E = 1.12(PW)^{0.27}$$

[IDAPA 58.01.01.702, 4/5/00]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Monitoring & Recordkeeping Requirements

3.2 None. The process is inherently in compliance. See the technical memorandum for explanation.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

4. EAST SULFURIC ACID PLANT**Summary Description**

The following is a narrative description of the East Sulfuric Acid Plant regulated in this Tier I operating permit. This description is for informational purposes only.

Approximately 50% of the sulfuric acid utilized at the Agrium Conda Phosphate Plant is currently manufactured by Nu-West at the East Sulfuric Acid Plant using a dual absorption contact process that burns elemental sulfur. The other 50% of the sulfuric acid used at the facility is purchased from a third party source.

Table 4.1 describes the devices used to control emissions from East Sulfuric Acid Plant.

Table 4.1 EMISSIONS UNITS AND EMISSIONS CONTROL DEVICES

Source Code	Emission Unit(s) / Process(es)	Emission Control Device
S-Se-1	East Sulfuric Acid Plant	Dual absorption contact process

Table 4.2 contains only a summary of the requirements that apply to the East Sulfuric Acid Plant. Specific permit requirements are listed below Table 4.2.

Table 4.2 APPLICABLE REQUIREMENTS SUMMARY

Permit Conditions	Parameter	Permit Limit / Standard Summary	Applicable Requirements Reference	Operating, Monitoring and Recordkeeping Requirements
4.1	Sulfur dioxide emissions	4 pounds per ton of sulfuric acid production 258 lb/hr 945 T/yr 28 pounds per ton of 100% sulfuric acid production	40 CFR 60.82 ⁽¹⁾ PTC No. P-040307 IDAPA 58.01.01.845	4.5 - 4.10 - 4.14
4.2	Sulfuric acid mist emissions	0.15 pounds per ton of sulfuric acid production	40 CFR 60.83	4.6, 4.10 - 4.13, 4.15
4.3	Visible emissions	10% opacity	40 CFR 60.83	4.6, 4.10 - 4.12

¹ If any requirement in this permit conflicts with any requirement contained in 40 CFR 60 the requirement in 40 CFR 60 shall control.

Permit Limits / Standard Summary**4.1 Sulfur Dioxide Emissions from the East Sulfuric Acid Plant**

- 4.1.1 Sulfur dioxide emissions shall not exceed four pounds per ton of 100% sulfuric acid production, as specified in 40 CFR 60.82(a). Compliance with this limit will also demonstrate compliance with the sulfur dioxide emission limit contained in IDAPA 58.01.01.845 (28 pounds SO₂ per ton of 100% sulfuric acid production).

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 4.1.2 Sulfur dioxide emissions shall not exceed 258 lb/hr and 945 tons per any consecutive 12-month period.

[40 CFR 60.82; IDAPA 58.01.01.845, 5/1/94; PTC No. P-040307, 12/10/04]

4.2 Sulfuric Acid Mist Emissions from the East Sulfuric Acid Plant

Sulfuric acid mist emissions from the East Sulfuric Acid Plant shall not exceed 0.15 lb per ton of 100% sulfuric acid production, as specified in 40 CFR 60.83(a)(1).

[40 CFR 60.83; PTC No. P-040307, 12/10/04]

4.3 Visible Emission Limits

Visible emission limits from the East Sulfuric Acid Plant shall not exceed 10% opacity as specified in 40 CFR 60.83(a)(2).

[40 CFR 60.83; PTC No. P-040307, 12/10/04]

4.4 PM - Process Weight PM Emissions Limitations

No person shall emit into the atmosphere from any process or process equipment commencing operation on or after October 1, 1979, particulate matter in excess of the amount shown by the following equations, where E is the allowable emission from the entire source in pounds per hour, and PW is the process weight in pounds per hour.

- a. If PW is less than 9,250 lb/hr,

$$E = 0.045(PW)^{0.6}$$

- b. If PW is equal to or greater than 9,250 lb/hr,

$$E = 1.10(PW)^{0.25}$$

[IDAPA 58.01.01.701, 4/5/00]

Operating Requirements

4.5 Production Rate Limit

The East Sulfuric Acid Plant shall have a maximum daily production rate of 1,550 tons per day.

[PTC No. P-040307, 12/10/04]

Monitoring & Recordkeeping Requirements

4.6 Performance Tests

- 4.6.1 Sulfur dioxide and sulfuric acid mist emission tests shall be performed during each 13-month period of the permit term using EPA Reference Methods 1, 2, 3, and 8, or DEQ approved alternative methods. All emission tests shall be performed at the process equipment's maximum operating capacity.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 4.6.2 Visible emissions shall be observed and recorded with the emissions test required in Permit Condition 4.6, using EPA Reference Method 9. A minimum of 24 observations shall be recorded.
- 4.6.3 The maximum production following each emission test shall not exceed 105% of the rate achieved during the test unless the following conditions are met, and this rate shall not exceed 1550 tons per day:
- 4.6.3.1 The sulfur dioxide monitor is calibrated at least once every 24 hours using certified test gases, one of which has a sulfur dioxide concentration equal or less than the expected stack gas sulfur dioxide concentration, and one of which has a sulfur dioxide concentration greater than the expected stack gas sulfur dioxide concentration.
- 4.6.3.2 Prior written approval by DEQ is received.
- 4.6.3.3 An emission test is performed at the requested increased production rate, and the test demonstrates that the continuous emission monitor is accurate at the increased rate.
- 4.6.3.4 Sulfur dioxide and acid mist emission limits will not be violated at the requested increased production rate.

[PTC No. P-040307, 12/10/04]

4.7 CEMS Requirement

- 4.7.1 A continuous monitoring system for the measurement of sulfur dioxide shall be installed, calibrated, maintained, and operated by the owner or operator. The pollutant gas used to prepare calibration gas mixtures under Performance Specification 2 and for calibration checks under 60.13(d), shall be sulfur dioxide (SO₂). Method 8 shall be used for conducting monitoring system performance evaluations under 60.13(c) except that only the sulfur dioxide portion of the Method 8 results shall be used. The span value shall be set at 1000 ppm of sulfur dioxide.
- 4.7.2 The owner or operator shall establish a conversion factor for the purpose of converting monitoring data into units of the applicable standard (kg/metric ton, lb/ton). The conversion factor shall be determined, as a minimum, three times daily by measuring the concentration of sulfur dioxide entering the converter using suitable methods (e.g., the Reich test, National Air Pollution Control Administration Publication No. 999-AP-13) and calculating the appropriate conversion factor for each 8-hour period as follows:

$$CF = k[(1.000 - 0.015r) / (r - s)]$$

where:

CF = conversion factor (kg/metric ton per ppm, lb/ton per ppm).

k = constant derived from material balance. For determining CF in metric units, k = 0.0653. For determining CF in English units, k = 0.1306.

r = percentage of sulfur dioxide by volume entering the gas converter. Appropriate corrections must be made for air injection plants subject to the Administrator's approval.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

s = percentage of sulfur dioxide by volume in the emissions to the atmosphere determined by the continuous monitoring system required under Permit Condition 4.7.1.

4.7.3 The owner or operator shall record all conversion factors and values under Permit Condition 4.7.2 from which they were computed (i.e., CF, r, and s).

4.7.4 Alternatively, a source that processes elemental sulfur or an ore that contains elemental sulfur and uses air to supply oxygen may use the following continuous emission monitoring approach and calculation procedures in determining SO₂ emission rates in terms of the standard. This procedure is not required, but is an alternative that would alleviate problems encountered in the measurement of gas velocities or production rate. Continuous emission monitoring systems for measuring SO₂, O₂, and CO₂ (if required) shall be installed, calibrated, maintained, and operated by the owner or operator and subjected to the certification procedures in Performance Specifications 2 and 3. The calibration procedure and span value for the SO₂ monitor shall be as specified in paragraph (b) of this section. The span value for CO₂ (if required) shall be 10% and for O₂ shall be 20.9% (air). A conversion factor based on process rate data is not necessary. Calculate the SO₂ emission rate as follows:

$$Es = (C, S) / [0.265 - (0.126 \%O_2) - (A \%CO_2)]$$

where:

Es = emission rate of SO₂, kg/metric ton (lb/ ton) of 100% of H₂SO₄ produced.

Cs = concentration of SO₂, kg/dscm (lb/dscf).

S = acid production rate factor, 368 dscm/metric ton (11,800 dscf/ton) of 100% H₂SO₄ produced.

% O₂ = oxygen concentration, percent dry basis.

A = auxiliary fuel factor,

= 0.00 for no fuel.

= 0.0226 for methane.

= 0.0217 for natural gas.

= 0.0196 for propane.

= 0.0172 for No 2 oil.

= 0.0161 for No 6 oil.

= 0.0148 for coal.

= 0.0126 for coke.

% CO₂ = carbon dioxide concentration, percent dry basis.

NOTE: It is necessary in some cases to convert measured concentration units to other units for these calculations. Use the following table for such conversions:

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

<u>From</u>	<u>To</u>	<u>Multiply by</u>
g/scm	kg/scm	10^{-3}
mg/scm	kg/scm	10^{-6}
ppm (SO ₂)	kg/scm	2.660×10^{-6}
ppm (SO ₂)	lb/scf	1.660×10^{-7}

- 4.7.5 For the purpose of reports under 40 CFR 60.7(c), periods of excess emissions shall be all three-hour periods (or the arithmetic average of three consecutive one-hour periods) during which the integrated average sulfur dioxide emissions exceed the applicable standards under 40 CFR 60.82.

[40 CFR 60.84; PTC No. P-040307, 12/10/04]

4.8 **Production Monitoring**

Each day, the permittee shall monitor and record the production of the East Sulfuric Acid Plant in tons/day.

[IDAPA 58.01.01.322.06, 5/1/94; PTC No. P-040307, 12/10/04]

4.9 **SO₂ Hourly and Annual Emission Rate Monitoring**

Using the CEMS required under Permit Condition 4.7, the Permittee shall monitor and record the SO₂ emissions from the East Sulfuric Acid Plant to demonstrate compliance with Permit Condition 4.1.2, as specified below:

- in pounds per hour; and
- in tons for each consecutive 12-month period;

[IDAPA 58.01.01.322.06, 5/1/94; PTC No. P-040307, 12/10/04]

4.10 **Test Methods and Procedures**

- 4.10.1 In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in Appendix A of 40 CFR 60 or other methods and procedures as specified in this section, except as provided in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in paragraph 4.10.3.

- 4.10.2 The owner or operator shall determine compliance with the SO₂, acid mist, and visible emission standards in Permit Conditions 4.1, 4.2, and 4.3 (60.82 and 60.83) as follows:

- (1) The emission rate (E) of acid mist or SO₂ shall be computed for each run using the following equation:

$$E = (CQ_{sd}) / (PK)$$

where:

- E = emission rate of acid mist or SO₂ kg/metric ton (lb/ton) of 100 % H₂SO₄ produced.
C = concentration of acid mist or SO₂, g/dscm (lb/dscf).
Q_{sd} = volumetric flow rate of the effluent gas, dscm/hr (dscf/hr).

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

P = production rate of 100 % H₂SO₄, metric ton/hr (ton/hr).

K = conversion factor, 1000 g/kg (1.0 lb/lb).

- (2) Method 8 shall be used to determine the acid mist and SO₂ concentrations (C's) and the volumetric flow rate (Q_{sd}) of the effluent gas. The moisture content may be considered to be zero. The sampling time and sample volume for each run shall be at least 60 minutes and 1.15 dscm (40.6 dscf).
- (3) Suitable methods shall be used to determine the production rate (P) of 100% H₂SO₄ for each run. Material balance over the production system shall be used to confirm the production rate.
- (4) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.

4.10.3 The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:

- (i) If a source processes elemental sulfur or an ore that contains elemental sulfur and uses air to supply oxygen, the following procedure may be used instead of determining the volumetric flow rate and production rate:
- (ii) The integrated technique of Method 3 is used to determine O₂ concentration and, if required, CO₂ concentration.
- (iii) The SO₂ or acid mist emission rate is calculated as described in 40 CFR 60.84(d), substituting the acid mist concentration for C(s) as appropriate.

[40 CFR 60.85]

Reporting

4.11 Performance Test Protocol

The permittee shall submit for approval to DEQ a source test protocol for each test required by Permit Condition 4.6. The test protocol shall be submitted to DEQ no later than 30 days prior to the date of the initial performance test. Once DEQ approves the test protocol, the permittee shall conduct all subsequent source tests in accordance with the approved protocol. The permittee may submit a new test protocol for review and approval in the event that there is any change in the protocol. The new test protocol shall be approved by DEQ prior to any testing in accordance with the new protocol.

[PTC No. P-040307, 12/10/04]

4.12 Performance Test Results

The data and results of all emissions tests shall be reported to DEQ within 30 days of the completion of the tests. The report shall also include continuous emission monitoring data, production rates, and visible emissions data.

[PTC No. P-040307, 12/10/04]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

4.13 Sulfur Dioxide Emissions Report

All three-hour running average sulfur dioxide emissions and quarterly emissions of sulfuric acid mist shall be reported to DEQ in a calendar-quarterly report. The quarterly emissions of sulfuric acid mist shall be calculated by using the most recent source test emission factor multiplied by the production rate. The report shall be received by DEQ no later than 30 days after each calendar quarter.

[PTC No. P-040307, 12/10/04]

4.14 CEMS Report

All repairs or changes to the continuous emissions monitoring systems (CEMS) and any calibration problem shall be reported to DEQ within seven days and shall be included in the quarterly report.

[PTC No. P-040307, 12/10/04]

PTC General Provisions

4.15 The permittee shall at all times (except as provided in the *Rules*) maintain in good working order and operate as efficiently as practicable, all treatment or control facilities or systems installed or used to achieve compliance with the terms and conditions of this permit and other applicable Idaho laws for the control of air pollution.

[PTC No. P-040307, 12/10/04]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

5. NEBRASKA BOILER (B-5)**Summary Description**

The following is a narrative description of the B-5 Nebraska boiler regulated in this Tier I operating permit. This description is for informational purposes only.

The "B-5" gas-fired boiler generates steam for the production of phosphoric acid. The B-5 boiler must meet the following specifications, or be of equivalent design subject to DEQ approval:

Manufacturer: Nebraska Boiler Company
Model Number: NSX-G-107-ECON
Rated Heat Input: 213.8 MMBtu/hr
Steam Capacity: 175,000 lb/hr
Fuel: Natural gas

Table 5.1 describes the devices used to control emissions from the Nebraska boiler.

Table 5.1 EMISSIONS UNITS AND EMISSIONS CONTROL DEVICES

Source Code	Emission Unit(s) / Process(es)	Emission Control Device
S-Nb-1	Nebraska boiler (B-5)	Low NO _x package boiler

Table 5.2 contains only a summary of the requirements that apply to the B-5 Nebraska boiler. Specific permit requirements are listed below Table 5.2.

Table 5.2 APPLICABLE REQUIREMENTS SUMMARY

Permit Conditions	Parameter	Permit Limit / Standard Summary	Applicable Requirements Reference	Operating, Monitoring and Recordkeeping Requirements
5.1	Nitrogen oxide emissions	0.20 lb/MMBtu 16.84 lb/hr 70.71 T/yr	40 CFR 60.44b ⁽¹⁾ PTC No. 029-00003, Permit Condition 2.2, 7/7/95	5.4, 5.5, 5.6, 5.7, 5.8, 5.9, 5.10, 5.11, 5.13, 5.14, 5.15, 5.16, 5.17, 5.18, 5.19, 5.20, 5.21, 5.22
5.2	Particulate matter emissions PM ₁₀ emissions SO ₂ emissions CO emissions VOC emissions	1.05 lb/hr, 4.42 T/yr 1.05 lb/hr, 4.42 T/yr 0.13 lb/hr, 0.53 T/yr 8.42 lb/hr, 35.4 T/yr 0.36 lb/hr, 1.50 T/yr	PTC No. 029-00003, Permit Condition 2.1, 7/7/95	5.5, 5.6, 5.12
5.3	Particulate matter	0.015 gr/dscf corrected to 3% oxygen	IDAPA 58.01.01.677	5.5

¹ If any requirement in this permit conflicts with any requirement contained in 40 CFR 60 the requirement in 40 CFR 60 shall control.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Permit Limits / Standard Summary

- 5.1 The NO_x emissions from the B-5 boiler stack shall not exceed 0.20 lb/MMBtu in accordance with Permit Condition 5.1.1 and the NO_x emission limits in Table 5.3.
- 5.1.1 On and after the date the initial performance test is completed, or is required to be completed under 40 CFR 60.8 (whichever comes first), the permittee shall not cause any gases that contain nitrogen oxides (expressed as NO₂) to be discharged into the atmosphere in excess of 0.10 pounds per million Btu (0.10 lb/MMBtu) heat input to the boiler at a low heat release rate (70,000 Btu/hr-ft³ or less), or in excess of 0.20 pounds per million Btu (0.20 lb/MMBtu) heat input to the boiler at a high heat release rate (greater than 70,000 Btu/hr-ft³).
[40 CFR 60.44b(a); PTC No. 029-00003, Section 2.2, 8/14/96]
- 5.1.2 Compliance with the emission limit in Permit Condition 5.1.1 is determined on a 30-day rolling average basis.
[40 CFR 60.44b(l)]
- 5.2 The PM, PM₁₀, SO₂, CO and VOC emissions from the B-5 boiler exhaust stack shall not exceed any corresponding emission limit listed in Table 5.3.
[PTC No. 029-00003, Section 2.1, 7/7/95]

Table 5.3 EMISSION LIMITS

Source Description	PM		PM ₁₀		SO ₂		NO _x		VOC		CO	
	lb/hr	T/yr	lb/hr	T/yr	lb/hr	T/yr	lb/hr	T/yr	lb/hr	T/yr	lb/hr	T/yr
B-5 Boiler	1.05	4.42	1.05	4.42	0.13	0.53	16.84	70.71	0.36	1.50	8.42	35.4

- 5.3 The PM emissions shall not exceed the grain-loading emission limits of 0.015 gr/dscf of effluent gas corrected to 3% oxygen by volume for natural gas.
[IDAPA 58.01.01.677, 5/1/94]

Operating Requirements

- 5.4 The boiler shall be equipped with a COEN low-NO_x burner, or a DEQ-approved equivalent for the control of NO_x emissions.
[PTC No. 029-00003, Section 1.2, 8/14/96]
- 5.5 The B-5 boiler shall only use natural gas as fuel.
[PTC No. 029-00003, Section 3.3, 7/7/95]
- 5.6 The B-5 boiler shall not burn more than 1,768,000,000 scf of natural gas fuel per year.
[PTC No. 029-00003, Section 3.4, 7/7/95]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Monitoring & Recordkeeping Requirements

5.7 NO_x Performance Test

Compliance with the NO_x emission standards under Permit Condition 5.1 (40 CFR 60.44b) of this permit shall be determined through performance testing under Permit Condition 5.8 or 5.9 (40 CFR 60.46b(e) or (g)). This performance test, and any subsequent performance tests conducted to demonstrate compliance with this permit, shall be performed in accordance with IDAPA 58.01.01.157.

[40 CFR 60.46b(c)]

5.8 To determine compliance with the emission limits for nitrogen oxides required under 40 CFR 60.44b, the owner or operator of an affected facility shall conduct the performance test as required under 40 CFR 60.8 using the continuous system for monitoring nitrogen oxides under Permit Condition 5.10 (40 CFR 60.48(b)).

- 1) In accordance with 40 CFR 60.46b(e)(4), following the date on which the initial performance test is completed or required to be completed under 40 CFR 60.8 of 40 CFR 60, whichever date comes first, the owner or operator of an affected facility which has a heat input capacity of 73 MW (250 MMBtu/hr) or less and which combusts natural gas, distillate oil, or residual oil having a nitrogen content of 0.30 weight percent or less shall upon request determine compliance with the nitrogen oxides standards under 40 CFR 60.44b through the use of a 30-day performance test. During periods when performance tests are not requested, nitrogen oxides emissions data collected pursuant to 40 CFR 60.48b(g)(1) or 40 CFR 60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the nitrogen oxides emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly nitrogen oxides emission data for the preceding 30 steam-generating unit operating days.

[40 CFR 60.46b(e)]

5.9 The owner or operator of an affected facility described in 40 CFR 60.44b(j) or 40 CFR 60.44b(k) shall demonstrate the maximum heat input capacity of the steam-generating unit by operating the facility at maximum capacity for 24 hours. The owner or operator of an affected facility shall determine the maximum heat input capacity using the heat loss method described in Sections 5 and 7.3 of the American Society for Mechanical Engineers (ASME) Power Test Codes 4.1 (see IBR 40 CFR 60.17(h)). This demonstration of maximum heat input capacity shall be made during the initial performance test for affected facilities that meet the criteria of 40 CFR 60.44b(j). It shall be made within 60 days after achieving the maximum production rate at which the affected facility will be operated, but no later than 180 days after initial start-up of each facility, for affected facilities meeting the criteria of 40 CFR 60.44b(k). Subsequent demonstrations may be required by the Administrator at any other time. If this demonstration indicates that the maximum heat input capacity of the affected facility is less than that stated by the manufacturer of the affected facility, the maximum heat input capacity determined during this demonstration shall be used to determine the capacity utilization rate for the affected facility. Otherwise, the maximum heat input capacity provided by the manufacturer is used.

[40 CFR 60.46b(g)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 5.10 The owner or operator of an affected facility that has a heat input capacity of 73 MW (250 MMBtu/hr) or less, and which has an annual capacity factor for residual oil having a nitrogen content of 0.30 weight percent or less, natural gas, distillate oil, or any mixture of these fuels, greater than 10% (0.10) shall:
- (1) Comply with the provisions of 40 CFR 60.48b(b) through 40 CFR 60.48b(f), or
 - (2) Monitor steam-generating unit operating conditions and predict nitrogen oxides emission rates as specified in a plan submitted pursuant to Permit Condition 5.15.2 (40 CFR 60.49b(c)).
[40 CFR 60.48b(g)]
- 5.11 The permittee shall monitor and record the following data as specified in 40 CFR 60.49b(g):
- 5.11.1 Calendar date.
- 5.11.2 The average hourly NO_x emission rates in lb/MMBtu and lb/hr.
- 5.11.3 The 30-day average NO_x emission rates calculated at the end of each operating day from measured or predicted hourly NO_x emission rates for the preceding 30 operating days.
- 5.11.4 Identification of boiler operating days when the average 30-day NO_x emission rates exceed the standard, with an explanation of the cause of the exceedance and the corrective action taken to remedy the cause of the exceedance.
- 5.11.5 Identification of the boiler operating days for which NO_x data have not been obtained, including the reasons for not obtaining sufficient data and a description of the correction actions taken.
- 5.11.6 A list of the times when data were excluded from the 30-day NO_x emission average calculations because of a unit start-up, shut-down, malfunction, or other reasons and the reasons for excluding data.
- 5.11.7 Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.
- 5.11.8 Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.
- 5.11.9 Description of any modifications to the continuous monitoring system which could affect the ability of the continuous monitoring system to comply with Performance Specifications 2 or 3.
- 5.11.10 Results of daily CEMS drift tests and quarterly accuracy assessments as required under Appendix F, Procedure 1.
[40 CFR 60.49b(g); PTC No. 029-00003, Section 4.4, 7/7/95]
- 5.12 The permittee shall monitor and record the cumulative volume of natural gas fuel consumption on a monthly basis and per each consecutive 12-month period.
[PTC No. 029-00003, Section 4.5, 7/7/95; IDAPA 58.01.01.322.06]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

5.13 Performance Tests

- 5.13.1 Within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup of such facility and at such other times as may be required by the Administrator under section 114 of the Act, the owner or operator of such facility shall conduct performance test(s) and furnish the Administrator a written report of the results of such performance test(s).

[40 CFR 60.8(a)]

- 5.13.2 Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart unless the Administrator:

- (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology,
- (2) approves the use of an equivalent method,
- (3) approves the use of an alternative method the results of which he has determined to be adequate for indicating whether a specific source is in compliance,
- (4) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Administrator's satisfaction that the affected facility is in compliance with the standard, or
- (5) approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in this paragraph shall be construed to abrogate the Administrator's authority to require testing under section 114 of the Clean Air Act.

[40 CFR 60.8(b)]

- 5.13.3 Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

- 5.13.4 The owner or operator of an affected facility shall provide the Administrator at least 30 days prior notice of any performance test, except as specified under other subparts, to afford the Administrator the opportunity to have an observer present. If after 30 days notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting the scheduled performance test, the owner or operator of an affected facility shall notify the Administrator (or delegated State or local agency) as soon as possible of any delay in the original test date, either by providing at least seven days prior notice of the rescheduled date of the performance test, or by arranging a rescheduled date with the Administrator (or delegated State or local agency) by mutual agreement.

[40 CFR 60.8(d)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

5.13.5 The owner or operator of an affected facility shall provide, or cause to be provided, performance testing facilities as follows:

- (1) Sampling ports adequate for test methods applicable to such facility. This includes (i) constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures and (ii) providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
- (2) Safe sampling platform(s).
- (3) Safe access to sampling platform(s).
- (4) Utilities for sampling and testing equipment.

[40 CFR 60.8(e)]

5.13.6 Unless otherwise specified in the applicable subpart, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic means of results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances, beyond the owner or operator's control, compliance may, upon the Administrator's approval, be determined using the arithmetic mean of the results of the two other runs.

[40 CFR 60.8(f)]

5.14 Compliance with Standards

At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

[40 CFR 60.11(d)]

5.15 For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in 40 CFR 60, nothing in 40 CFR 60 shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.

[40 CFR 60.11(g)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

5.16 Circumvention

No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

5.17 40 CFR 60, Subpart A, Monitoring Requirements

For the purposes of this section, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of this section upon promulgation of performance specifications for continuous monitoring systems under Appendix B to 40 CFR 60, and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F to 40 CFR 60, unless specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.

[40 CFR 60.13(a)]

- 5.17.1 All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests under 40 CFR 60.8. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device.

[40 CFR 60.13(b)]

- 5.17.2 Owners and operators of a CEMS installed in accordance with the provisions of 40 CFR 60, must automatically check the zero (or low level value between zero and 20% of span value) and span (50 to 100% of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span must, as a minimum, be adjusted whenever either the 24-hour zero drift or the 24-hour span drift exceeds two times the limit of the applicable performance specification in Appendix B of 40 CFR 60. The system must allow the amount of the excess zero and span drift to be recorded and quantified whenever specified.

[40 CFR 60.13(d)]

- 5.17.3 Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under paragraph (d) of this section, all continuous monitoring systems shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

- (1) In accordance with 40 CFR 60.13(e)(2), all continuous monitoring systems referenced by paragraph (c) of this section for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 5.17.4 All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.

[40 CFR 60.13(f)]

- 5.17.5 Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to six-minute averages and for continuous monitoring systems other than opacity to one-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each six-minute period. For continuous monitoring systems other than opacity, one-hour averages shall be computed from four or more data points equally spaced over each one-hour period. Data recorded during periods of continuous system breakdown, repair, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. For owners and operators complying with the requirements in 40 CFR 60.7(f)(1) or (2), data averages must include any data recorded during periods of monitor breakdown or malfunction.

An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or nonreduced form (e.g., ppm pollutant and percent O₂ or ng of pollutant per J of heat input). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1% opacity).

[40 CFR 60.13(h)]

- 5.17.6 After receipt and consideration of written application, the Administrator may approve alternatives to any monitoring procedures or requirements of 40 CFR 60 including, but not limited to the following:
- (1) Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by 40 CFR 60 would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases
 - (2) Alternative monitoring requirements when the affected facility is infrequently operated.
 - (3) Alternative monitoring requirements to accommodate continuous monitoring systems that require additional measurements to correct for stack moisture conditions.
 - (4) Alternative locations for installing continuous monitoring systems or monitoring devices when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative measurements.
 - (5) Alternative methods of converting pollutant concentration measurements to units of the standards.
 - (6) Alternative procedures for performing daily checks of zero and span drift that do not involve use of span gases or test cells.
 - (7) Alternatives to the A.S.T.M. test methods or sampling procedures specified by any subpart.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (8) Alternative continuous monitoring systems that do not meet the design or performance requirements in Performance Specification 1, Appendix B, but adequately demonstrate a definite and consistent relationship between its measurements and the measurements of opacity by a system complying with the requirements in Performance Specification 1. The Administrator may require that such demonstration be performed for each affected facility.
- (9) Alternative monitoring requirements when the effluent from a single affected facility or the combined effluent from two or more affected facilities is released to the atmosphere through more than one point.

[40 CFR 60.13(l)]

5.17.7 An alternative to the relative accuracy (RA) test specified in Performance Specification 2 of 40 CFR 60, Appendix B may requested as follows:

- (1) An alternative to the reference method tests for determining RA is available for sources with emission rates demonstrated to be less than 50% of the applicable standard. A source owner or operator may petition the Administrator to waive the relative accuracy test in Section 8.4 of Performance Specification 2 and substitute the procedures in Section 16.0 if the results of a performance test conducted according to the requirements in 40 CFR 60.8 or other tests performed following the criteria in 40 CFR 60.8 demonstrate that the emission rate of the pollutant of interest in the units of the applicable standard is less than 50% of the applicable standard. For sources subject to standards expressed as control efficiency levels, a source owner or operator may petition the Administrator to waive the RA test and substitute the procedures in Section 16.0 of Performance Specification 2 if the control device exhaust emission rate is less than 50% of the level needed to meet the control efficiency requirement. The alternative procedures do not apply if the continuous emission monitoring system is used to determine compliance continuously with the applicable standard. The petition to waive the RA test shall include a detailed description of the procedures to be applied. Included shall be location and procedure for conducting the alternative, the concentration or response levels of the alternative RA materials, and the other equipment checks included in the alternative procedure. The Administrator will review the petition for completeness and applicability. The determination to grant a waiver will depend on the intended use of the CEMS data (e.g., data collection purposes other than NSPS) and may require specifications more stringent than in Performance Specification 2 (e.g., the application emission limit is more stringent than NSPS).
- (2) The waiver of a CEMS RA test will be reviewed and may be rescinded at such time, following successful completion of the alternative RA procedure, that the CEMS data indicate that the source emissions are approaching the level. The criterion for reviewing the waiver is the collection of CEMS data showing that emissions have exceeded 70% of the applicable standard for seven, consecutive, averaging periods as specified by the applicable regulation(s). For sources subject to standards expressed as control efficiency levels, the criterion for reviewing the waiver is the collection of CEMS data showing that exhaust emissions have exceeded 70% of the level needed to meet the control efficiency requirement for seven consecutive, averaging periods as specified by the applicable regulation(s) (e.g., 40 CFR 60.45(g)(2) and (3), 40 CFR 60.73(e), and 40 CFR 60.84(e)). It is the responsibility of the source operator to maintain records and determine the level of emissions relative to the criterion on the waiver of RA testing. If this criterion is exceeded, the owner or operator must notify the Administrator within 10 days of such occurrence and include a description of the nature and cause of the increasing emissions. The Administrator will review the notification and may rescind the waiver and require the owner or operator to conduct a RA test of the CEMS as specified in Section 8.4 of Performance Specification 2.

[40 CFR 60.13(j)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Reporting

5.18 The owner or operator of each affected facility shall submit notification of the date of initial startup, as provided by 40 CFR 60.7. This notification shall include:

- (1) The design heat input capacity of the affected facility and identification of the fuels to be combusted in the affected facility,
- (2) In accordance with 40 CFR 60.49b(a)(3), the annual capacity factor at which the owner or operator anticipates operating the facility based on all fuels fired and based on each individual fuel fired, and,

[40 CFR 60.49b(a)]

5.18.1 The owner or operator of each affected facility subject to sulfur dioxide, particulate matter, and/or nitrogen oxides emission limits under 40 CFR 60.42b, 40 CFR 60.43b, and 40 CFR 60.44b shall submit to the Administrator the performance test data from the initial performance test and the performance evaluation of the CEMS using the applicable performance specifications in Appendix B. The owner or operator of each affected facility described in 40 CFR 60.44b(j) or 40 CFR 60.44b(k) shall submit to the Administrator the maximum heat input capacity data from the demonstration of the maximum heat input capacity of the affected facility.

[40 CFR 60.49b(b)]

5.18.2 The owner or operator of each affected facility subject to the nitrogen oxides standard of 60.44b who seeks to demonstrate compliance with those standards through the monitoring of steam generating unit operating conditions under the provisions of 40 CFR 60.48b(g)(2) shall submit to the Administrator for approval a plan that identifies the operating conditions to be monitored under 40 CFR 60.48b(g)(2) and the records to be maintained under 40 CFR 60.49b(j). This plan shall be submitted to the Administrator for approval within 360 days of the initial startup of the affected facility. The plan shall:

- (1) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and nitrogen oxides emission rates (i.e., ng/J or lbs/million Btu heat input). Steam-generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas oxygen level);
- (2) Include the data and information which the owner or operator used to identify the relationship between nitrogen oxides emission rates and these operating conditions;
- (3) Identify how these operating conditions, including steam generating unit load, will be monitored under 40 CFR 60.48b(g) on an hourly basis by the owner or operator during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam-generating unit load, that will be maintained by the owner or operator under 40 CFR 60.49b(j).

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

If the plan is approved, the owner or operator shall maintain records of predicted nitrogen oxide emission rates and the monitored operating conditions, including steam generating unit load, identified in the plan.

[40 CFR 60.49b(c)]

- 5.18.3 The owner or operator of an affected facility shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for coal, distillate oil, residual oil, natural gas, wood, and municipal-type solid waste for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.

[40 CFR 60.49b(a)-(d)]

- 5.19 The owner or operator of any affected facility in any category listed in Paragraphs (h)(1) or (2) of this section is required to submit excess emission reports for any excess emissions which occurred during the reporting period.

- (1) Any affected facility subject to the opacity standards under 40 CFR 60.43b(e) or to the operating parameter monitoring requirements under 40 CFR 60.13(i)(1).
- (2) Any affected facility that is subject to the nitrogen oxides standard of 40 CFR 60.44b;
 - (i) Combusts natural gas, distillate oil, or residual oil with a nitrogen content of 0.3 weight percent or less; or
 - (ii) Has a heat input capacity of 73 MW (250 million Btu/hour) or less, and is required to monitor nitrogen oxides emissions on a continuous basis under 40 CFR 60.48b(g)(1) or steam generating unit operating conditions under 40 CFR 60.48b(g)(2).
- (3) Not applicable.
- (4) For purposes of 40 CFR 60.48b(g)(1), excess emissions are defined as any calculated 30-day rolling average nitrogen oxides emission rate, as determined under 40 CFR 60.46b(e), which exceeds the applicable emission limits in 40 CFR 60.44b.

[40 CFR 60.49b(h)]

- 5.20 The owner or operator of any affected facility subject to the continuous monitoring requirements for nitrogen oxides under 40 CFR 60.48(b) shall submit reports containing the information recorded under paragraph (g) of this section.

[40 CFR 60.49b(i)]

5.21 Address

- 5.21.1 All requests, reports, applications, submittals, and other communications to the Administrator pursuant to 40 CFR 60 shall be submitted in duplicate to the appropriate Regional Office of the EPA to the attention of the Director of the Division indicated in the following list of EPA Regional Offices. Copies of all information required to be submitted to the EPA for applicable NSPS requirements, shall also be submitted to DEQ at the address given in Section 1 of this permit.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Region 10
Director, Air and Waste Management Division
EPA
1200 Sixth Ave.
Seattle, WA 98101

[40 CFR 60.4(a); IDAPA 58.01.01.322.08]

5.22 Notification and Recordkeeping

Any owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification or, if acceptable to both the Administrator and the owner or operator of a source, electronic notification, as follows:

- (1) A notification of the date construction (or reconstruction as defined under 40 CFR 60.15 of an affected facility is commenced postmarked no later than 30 days after such date. This requirement shall not apply in the case of mass-produced facilities which are purchased in completed form.
- (2) (Reserved).
- (3) A notification of the actual date of initial startup of an affected facility postmarked within 15 days after such date.
- (4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.
- (5) A notification of the date upon which demonstration of the continuous monitoring system performance commences in accordance with 40 CFR 60.13(c). Notification shall be postmarked not less than 30 days prior to such date.
- (6) A notification of the anticipated date for conducting the opacity observations required by 40 CFR 60.11(e)(1) of 40 CFR 60. The notification shall also include, if appropriate, a request for the Administrator to provide a visible emissions reader during a performance test. The notification shall be postmarked not less than 30 days prior to such date.
- (7) A notification that continuous opacity monitoring system data results will be used to determine compliance with the applicable opacity standard during a performance test required by 40 CFR 60.8 in lieu of Method 9 observation data as allowed by 40 CFR 60.11(e)(5) of 40 CFR 60. This notification shall be post-marked not less than 30 days prior to the date of the performance test.

[40 CFR 60.7(a)]

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 5.22.1 Any owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative. [40 CFR 60.7(b)]
- 5.22.2 Each owner or operator required to install a continuous monitoring device shall submit excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or summary report form (see paragraph (d) of this section) to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each six-month period. Written reports of excess emissions shall include the following information:
- (1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
 - (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
 - (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
 - (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report. [40 CFR 60.7(c)]
- 5.22.3 The summary report form shall contain the information and be in the format shown in Figure 1 unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.
- (1) If the total duration of excess emissions for the reporting period is less than 1% of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5% of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.
 - (2) If the total duration of excess emissions for the reporting period is 1% or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5% or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308**Permittee:** Nu-West; Agrium**Facility ID No.:** 029-00003**Date Issued:** April 8, 2005**Location:** Soda Springs, ID**Date Expires:** October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

Summary Report - Gaseous and Opacity Excess Emission and Monitoring System PerformancePollutant (Circle One: SO₂ / NO_x / TRS / H₂S / CO / Opacity)

Reporting period dates: From _____ to _____

Company: _____

Emission Limitation: _____

Address: _____

Monitor Manufacturer and Model No.: _____

Date of Latest CMS Certification or Audit: _____

Process Unit(s) Description: _____

Total source operating time in reporting period¹: _____**Emission Data Summary¹****CMS Performance Summary¹**

1. Duration of excess emissions in reporting due to:

- a. Startup/shutdown _____
- b. Control equipment problems _____
- c. Process problems _____
- d. Other known causes _____
- e. Unknown causes _____

2. Total duration of excess emission _____

3. Total duration of excess emissions
x (100) [Total source operating time] %²

1. CMS downtime in reporting period due to:

- a. Monitor equipment malfunctions _____
- b. Non-Monitor equipment malfunctions _____
- c. Quality assurance calibration _____
- d. Other known causes _____
- e. Unknown causes _____

2. Total CMS downtime _____

3. [Total CMS Downtime] x (100)
[Total source operating time] %²

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1% or greater of the total operating time or the total CMS downtime is 5% or greater of the total operating time, both the summary report form and the excess emission report described in 40 CFR 60.7(c) shall be submitted.

On a separate page, describe any changes since last quarter in CMS, process or controls. I certify that the information contained in this report is true, accurate, and complete.

Name_____
Signature_____
Title_____
Date**[40 CFR 60.7(d)]**

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- 5.22.4 (1) Notwithstanding the frequency of reporting requirements specified in paragraph (c) of this section, an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:
- (i) For one full year (e.g., four quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under 40 CFR 60 continually demonstrate that the facility is in compliance with the applicable standard;
 - (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60 Subpart A and the applicable standard; and
 - (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in paragraph (e)(2) of this section.
- (2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.
- (3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in paragraphs (e)(1) and (e)(2) of this section.

[40 CFR 60.7(e)]

- 5.22.5 Any owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records, except as follows;

AIR QUALITY TIER I OPERATING PERMIT NUMBER: T1-040308

Permittee: Nu-West; Agrium

Facility ID No.: 029-00003

Date Issued: April 8, 2005

Location: Soda Springs, ID

Date Expires: October 28, 2006

The permittee is hereby allowed to operate the equipment described herein subject to all terms and conditions of the permit.

- (1) This paragraph applies to owners or operators required to install a continuous emissions monitoring system (CEMS) where the CEMS installed is automated, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. An automated CEMS records and reduces the measured data to the form of the pollutant emission standard through the use of a computerized data acquisition system. In lieu of maintaining a file of all CEMS subhourly measurements as required under paragraph (f) of this section, the owner or operator shall retain the most recent consecutive three averaging periods of subhourly measurements and a file that contains a hard copy of the data acquisition system algorithm used to reduce the measured data into the reportable form of the standard.
- (2) This paragraph applies to owners or operators required to install a CEMS where the measured data is manually reduced to obtain the reportable form of the standard, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. In lieu of maintaining a file of all CEMS subhourly measurements as required under paragraph (f) of this section, the owner or operator shall retain all subhourly measurements for the most recent reporting period. The subhourly measurements shall be retained for 120 days from the date of the most recent summary or excess emission report submitted to the Administrator.
- (3) The Administrator or delegated authority, upon notification to the source, may require the owner or operator to maintain all measurements as required by paragraph (f) of this section, if the Administrator or the delegated authority determines these records are required to more accurately assess the compliance status of the affected source.

[40 CFR 60.7(f)]

- 5.22.6 (g) If notification substantially similar to that in paragraph (a) of this section is required by any other State or local agency, sending the Administrator a copy of that notification will satisfy the requirements of Paragraph (a) of this section.

[40 CFR 60.7(g)]

- 5.22.7 (h) Individual subparts of 40 CFR 60 may include specific provisions which clarify or make inapplicable the provisions set forth in this section.

[40 CFR 60.7(h)]

PTC General Provisions

- 5.23 The permittee shall at all times (except as provided in the *Rules*) maintain in good working order and operate as efficiently as practicable, all treatment or control facilities or systems installed or used to achieve compliance with the terms and conditions of this permit and other applicable Idaho laws for the control of air pollution.

[PTC No. 029-00003, General Provision B, 7/7/95]

- 5.24 The performance tests will be performed at the maximum production rate. If this maximum rate is not achieved during testing, the allowable production rate will be limited to the production rate attained during testing.

[PTC No. 029-00003, General Provision F, 7/7/95]